

EQUIPMENT PAT TEST RESULTS / CERTIFICATE	INSPECTION & TEST DATE: 8/01/20	NEXT TEST DUE: 7/01/21	TEST EQUIPMENT USED:	PAT-IT XPAT05121608	TESTED BY:	JW	CLIENT: THE CHILLBILLIES , Samares, The Lees, Boughton Aluph, Kent TN25 4HX
---	---	-------------------------------	-----------------------------	-------------------------------	-------------------	-----------	--

SERIAL NO / Decription	MAKE & MODEL	VOLTAGE (V)	RATING (A)	FUSE RATING (A)	INSULATION RESISTANCE.	EARTH CONTINUITY.	PLUG, FLEX & BODY.	OK TO USE?	COMMENTS
Keyboard	CASIO PRIVIA PX300	240	N/A	N/A	PASS	N/A	OK	YES	
Amplifier	AMPEG STV4 PRO c/w LEAD	240		5	PASS	PASS	OK	YES	
Monitor Amp	POWER WORKS	240	425va	5	PASS	PASS	OK	YES	
Amplifier	MARSHALL AMP c/ w LEAD	230	225w	5	PASS	PASS	OK	YES	
Mixer	ALTO 1202 Mixer	230		5	PASS	PASS	OK	YES	
Speaker (Active) GNX05743	RCF ART Series	230	750	5	PASS	PASS	OK	YES	
Speaker (Active)	RCF ART Series	230	750	5	PASS	PASS	OK	YES	
Amplifier	SubZero Monitor Amp	240	120 w	5	PASS	PASS	OK	YES	
Plug Board	4-WAY Master Plug Ext	240		13	PASS	PASS	OK	YES	
Cable Reel	15m Reel.	240		13	PASS	PASS	OK	YES	
Cable Reel	4m 13A cable Reel	240		13	PASS	PASS	OK	YES	
Lamp	K&M Lamp	240		3	PASS	DI	OK	YES	

EQUIPMENT PAT TEST RESULTS / CERTIFICATE	INSPECTION & TEST DATE: 8/01/20	NEXT TEST DUE: 7/01/21	TEST EQUIPMENT USED:	PAT-IT XPAT05121608	TESTED BY:	JW	CLIENT: THE CHILLBILLIES , Samares, The Lees, Boughton Aluph, Kent TN25 4HX
---	---	-------------------------------	-----------------------------	-------------------------------	-------------------	-----------	--

IEC	IEC Leads x4	240		5	PASS	PASS	OK	YES
Plug Board	4-Way Master Plug ext	240		13	PASS	PASS	OK	YES
Monitor	Beringer Active B205D	240	180w	5	PASS	PASS	OK	YES