

| | | | | | | |
|---|---|------------------------------------|-----------------------------|-------------------------------|-------------------------|--|
| EQUIPMENT PAT TEST RESULTS / CERTIFICATE | INSPECTION & TEST DATE: 27/2/2021 | NEXT TEST DUE: 26/2/2022 | TEST EQUIPMENT USED: | PAT-IT XPAT05121608 | TESTED BY: JW | CLIENT: THE CHILLBILLIES , Samares, The Lees, Boughton Aluph, Kent TN25 4HX |
|---|---|------------------------------------|-----------------------------|-------------------------------|-------------------------|--|

| SERIAL NO / Description | MAKE & MODEL | VOLTAGE (V) | RATING (A) | FUSE RATING (A) | INSULATION RESISTANCE. | EARTH CONTINUITY. | PLUG, FLEX & BODY. | OK TO USE? | COMMENTS |
|---------------------------|-------------------------|-------------|------------|-----------------|------------------------|-------------------|--------------------|------------|----------|
| Keyboard | CASIO PRIVIA PX300 | 240 | N/A | N/A | PASS | N/A | OK | YES | |
| Amplifier | AMPEG STV4 PRO c/w LEAD | 240 | | 5 | PASS | PASS | OK | YES | |
| Monitor Amp | POWER WORKS | 240 | 425va | 5 | PASS | PASS | OK | YES | |
| Amplifier | MARSHALL AMP c/ w LEAD | 230 | 225w | 5 | PASS | PASS | OK | YES | |
| Mixer | ALTO 1202 Mixer | 230 | | 5 | PASS | PASS | OK | YES | |
| Speaker (Active) GNX05743 | RCF ART Series | 230 | 750 | 5 | PASS | PASS | OK | YES | |
| Speaker (Active) | RCF ART Series | 230 | 750 | 5 | PASS | PASS | OK | YES | |
| Amplifier | SubZero Monitor Amp | 240 | 120 w | 5 | PASS | PASS | OK | YES | |
| Plug Board | 4-WAY Master Plug Ext | 240 | | 13 | PASS | PASS | OK | YES | |
| Cable Reel | 15m Reel. | 240 | | 13 | PASS | PASS | OK | YES | |
| Cable Reel | 4m 13A cable Reel | 240 | | 13 | PASS | PASS | OK | YES | |
| Lamp | K&M Lamp | 240 | | 3 | PASS | DI | OK | YES | |

| | | | | | | |
|---|---|------------------------------------|-----------------------------|-------------------------------|-------------------------|--|
| EQUIPMENT PAT TEST RESULTS / CERTIFICATE | INSPECTION & TEST DATE: 27/2/2021 | NEXT TEST DUE: 26/2/2022 | TEST EQUIPMENT USED: | PAT-IT XPAT05121608 | TESTED BY: JW | CLIENT: THE CHILLBILLIES , Samares, The Lees, Boughton Aluph, Kent TN25 4HX |
|---|---|------------------------------------|-----------------------------|-------------------------------|-------------------------|--|

| | | | | | | | | | |
|-------------------|-----------------------|-----|------|----|------|------|----|-----|--|
| IEC | IEC Leads x4 | 240 | | 5 | PASS | PASS | OK | YES | |
| Plug Board | 4-Way Master Plug ext | 240 | | 13 | PASS | PASS | OK | YES | |
| Monitor | Beringer Active B205D | 240 | 180w | 5 | PASS | PASS | OK | YES | |